



DELHI JAL BOARD: GNCTD
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54



TEST REPORT

Sample ID	Ref. No. D.J.B/DOCC/Wzd/2025-26/Paid-34-35		
Location /Address of Sample	Savita Public School, opp. Street No.3, Main Road, Wazirabad, Delhi-110084		
Letter Reference No.	SPS/R/2025/264	Ref. Letter Date	29.04.2025
Challan No.	55	Challan Date	08.05.2025
Sample Collection date	09.05.2025	Analysis start date	09.05.2025
Any other Information	-	Analysis end date	11.05.2025
		Reporting date	12.05.2025

TEST RESULTS

S.No	Parameters	Unit	As per the IS 10500		Inlet (DIB Supply)	Outlet (Water Cooler)
			Acceptable limit	Permissible limit		
1	Colour	CU	5(Max)	15(Max)	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	4.4	2.9
4	pH at 25 °C	-	6.5-8.5	No relaxation	7.47	7.42
5	Electrical Conductivity	µS/cm	-	-	516	500
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	335	325
7	Total Alkalinity	mg/L	200(Max)	600(Max)	130	124
8	Total Hardness	mg/L	200(Max)	600(Max)	140	134
9	Calcium as Ca	mg/L	75(Max)	200(Max)	37	35
10	Magnesium as Mg	mg/L	30(Max)	100(Max)	10	8
11	Iron	mg/L	1.0(Max)	No relaxation	0.10	0.10
12	Chloride	mg/L	250(Max)	1000(Max)	66	63
13	Fluoride	mg/L	1.0(Max)	1.5(Max)	0.36	0.37
14	Ammonical-Nitrogen	mg/L	0.5(Max)	No relaxation	BDL	BDL
15	Nitrate	mg/L	45(Max)	No relaxation	6.6	6.4
16	Sulphate	mg/L	200(Max)	400(Max)	37.5	32.8
17	Residual Chlorine	mg/L	0.2(Min.)	1.0(Max)	0.45	0.30
18	Coliform Count at 37°(MPN)	/100 mL	Absent	No relaxation	0	0

*BDL=Below Detection Limit

End of Report

Remarks: Samples confirm specification for tested parameters and can be considered for the drinking purpose.

[Signature]
Tested by
Lab.Tech.

[Signature]
Verified for Chemical parameters
Asstt.Chemist

[Signature]
Verified for MPN
Asstt.Bact.

[Signature]
Authorized by
Chemist

[Signature]
Principal
Savita Public School
Main Road, Wazirabad,
Delhi-110084

[Signature]
Manager
Savita Public School
Main Road, Wazirabad,
Delhi-110084
Chief Water Analyst
Laboratory of N.C.T. of Delhi
Wazirabad, Wazirabad

ACWA(W2D)



**MUNICIPAL CORPORATION OF DELHI
(PUBLIC HEALTH DEPARTMENT: CIVIL LINES ZONE)
16 RAJ PUR ROAD, DELHI - 110054**

DHO/CLZ/2025/189..

Dated: 24/4/25

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by public health inspector Civil line zone from Public Health Department, inspected the M/S Savita Public School situated at Opp.Street no. -3, Main Road, Wazirabad Delhi-110084 on 22.04. 2025 and found that the school is running under sanitary and hygienic conditions from health point of view. School has safe drinking water facilities from the students and members of staff of the institution and his maintaining the hygiene and sanitation condition in the school building and the campus.

The above certificate is valid from 1 year from date of issue.

Asst.Manager
M/S Savita Public School
at Opp.Street no. -3, Main Road,
Wazirabad Delhi-110084


**Dy. Health Officer
Civil Lines Zone**

Deputy Health Officer
Civil Lines Zone
Municipal Corporation of Delhi
16, Rajpur Road, Delhi-1100


**Principal
Savita Public School
Main Road, Wazirabad,
Delhi-84**


**Manager
Savita Public School
Main Road, Wazirabad,
Delhi-110084**